


APPENDIX-VIII

**PROFORMA REGARDING SAFE DRINKING WATER CERTIFICATE**

No: SE/PIU/KUWSMP/KUIDFC/NOC/2025-26/822 Date: 24-06-2025

It is certified that an inspection team headed by SHRI. R.P JADHAV, SUPERINTENDING ENGINEER, KUWSMP- KUI DFC (Name of officers with designation) from Karnataka Urban Infrastructure Development & Finance Corporation Ltd, Project implementation Unit, KUWSMP, Kalaburagi (Name of Department/office) inspected the SHRI.DAMODAR RAGHOJI MEMORIAL SCHOOL, BEHIND TV STATION, HUMANABAD RING ROAD, REVANSIDDESHWAR COLONY KALABURAGI (Name & Address of the school) on 16-06-2025 and found that the SHRI. DAMODAR RAGHOJI MEMORIAL SCHOOL, (Name of School) has safe drinking water facilities for the students and members of staff of the institution.

The above valid for a period of One (1) year.

Signature with Seal  **Superintending Engineer**  
**PIU, KUWSMP, KUIDFC,**  
**Kalaburagi**


Name : R.P. JADHAV

Designation : SUPERINTENDING ENGINEER

To,

The Principal  
SHRI. DAMODAR RAGHOJI MEMORIAL SCHOOL, BEHIND TV STATION,  
HUMANABAD RING ROAD, REVANSIDDESHWAR COLONY KALABURAGI

  
**PRINCIPAL**  
**SHRI DAMODAR RAGHOJI**  
**MEMORIAL SCHOOL**  
CBSE AFFILIATION NO: 831093

  
**MANAGER**  
**SHRI DAMODAR RAGHOJI MEMORIAL**  
**CBSE SCHOOL, BEHIND T.V. STATION**  
**HUMNABAD RING ROAD**  
**KALABURAGI-585104**  
CBSE AFFILIATION NO: 831093





W370 #

SE

EE-N

TA

MGR

# **KALABURAGI DISTRICT WATER QUALITY TESTING LABORATORY** **RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK**

Opp. KGB Bank, Kusnoor Road, Kalaburagi-585105  
 Email ID : rdwsd.wqmcpkalaburagi@gmail.com

To,  
 The Executive Engineer,  
 PIU, KUWSMP, KUIDFC,  
 Kalaburagi  
 Location: Raghoji School

Report date: 18.06.2025  
 Report Number: 0005  
 Reference: By Hand  
 Sample receipt date: 16.06.2025  
 Sample code: KBR 25JUN0005  
 Date of Sampling: 16.06.2025  
 Analysis start date: 17.06.2025  
 Analysis completion date: 17.06.2025  
 Environmental Condition: Temp-24.9 °C  
 Sample collection protocol: APHA METHOD

Sample Particulars: Filter(RO) Water

Sample quantity: 1Litre

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
-------	------	---------	------------------------------------------	-------------------------------------------	----------

Description: Clear Sample

1.	pH Value @Temp 24.9 °C	7.11	6.5-8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, $\mu S/cm$ @ Temp 24.9 °C	100	—	—	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	01	5	15	IS 3025 (Part-4) :2023
5.	Turbidity, NTU	0.1	1	5	IS 3025 (Part-10) :2023
6.	Total Dissolved Solids@ 180°C, mg/l	64	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as $CaCO_3$ , mg/l	32.32	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as $CaCO_3$ , mg/l	44.47	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	8.1	75	200	IS 3025 (Part-40) : 1991
10.	Magnesium as Mg, mg/l	5.89	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	14.1	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as $SO_4$ , mg/l	<1	200	400	IS 3025 (Part-24) : 2022
13.	Fluoride as F, mg/l	0.1	1	1.5	APHA 24 <sup>th</sup> Edition
14.	Nitrate as $NO_3$ , mg/l	5.39	45	No relaxation	APHA 24th Edition
15.	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks : The above Tested Parameters Coforms Acceptable Limit of IS 10500:2012 RA:2018 Drinking Water Specification.

*Rachamma*

Authorized Signatory:  
 Technical Manager:(Rachamma Manchal)  
 Junior Analyst:(Saibanna)

Note:

RDWSD/WQMSP/DR-01

- The above results relate only to the sample tested & sample is drawn by the laboratory.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

\*\*\*End of Report\*\*\*

Page 1 of 1

**PRINCIPAL**

SHRI DAMODAR RAGHOJI  
 MEMORIAL SCHOOL  
 CBSE AFFILIATION NO: 831093

**MANAGER**

SHRI DAMODAR RAGHOJI MEMORIAL  
 CBSE SCHOOL, BEHIND T.V. STATION  
 HUMNABAD RING ROAD  
 KALABURAGI-585104  
 CBSE AFFILIATION NO: 831093